

LEGEND

- ① ANCHOR BLOCKING – SEE STANDARD DETAIL 26.02.
- ② TIE ROD ANCHORS – SEE STANDARD DETAIL 26.03.
- ③ AWWA C-509 RESILIENT WEDGE GATE VALVE.

NOTES:

1. ALL PIPE AND FITTINGS USED INSIDE THE ENCLOSURE SHALL BE FLANGED DUCTILE IRON. CONCRETE FOR SUPPORTS AND ANCHORS SHALL BE 3000 P.S.I.
2. ALL NON-FLANGED FITTINGS SHALL BE TIED WITH THREADED ROD TO ADJACENT FITTINGS AS GENERALLY SHOWN ON THIS SHEET. MEGALUG OR APPROVED EQUAL MAY BE SUBSTITUTED FOR TIE RODS AT MECHANICAL JOINTS.
3. ALL DIMENSIONS SHALL BE VERIFIED BY CONTRACTOR.
4. ONE ACCESS DOOR KEY SHALL BE SUBMITTED TO THE UTILITIES METER SUPERVISOR.
5. THE RPDA INSTALLATION MUST BE INSPECTED BY THE UTILITIES DEPARTMENT.
6. THE RPDA INSTALLATION IS PRIVATE AND WILL NOT BE OWNED/MAINTAINED BY THE CITY OF LYNCHBURG.



THE CITY OF LYNCHBURG

RPDA—FOR INDEPENDENT FIRE SERVICE
OR PRIVATE HYDRANT INSTALLATION
WITH DOMESTIC AND IRRIGATION SERVICES

USE WITH THE CITY OF LYNCHBURG STANDARD SPECIFICATIONS ONLY

SCALE:
NOT TO SCALE

REVISION DATE:
11-06-2006

DETAIL #
26.20B

SHEET #:
2 OF 2